

Monthly UST Inspection Report/Log		Staple Liquid Status Report here	
Inspector Name:		Operator ID#:	Inspection Date/Time:
Inspector Type:	Class A Operator <input type="checkbox"/>	Class B Operator <input type="checkbox"/>	Class A/B Operator <input type="checkbox"/>
Other inspector under the direction of a Class A, B or A/B Operator <input type="checkbox"/>			
Name of Class A, B or A/B Operator directing inspection:		Operator ID#:	
1. Electronic Monitoring Equipment (as applicable: interstitial space monitoring, in-tank monitoring, liquid sensors monitoring sumps and spill buckets, and impressed current cathodic protection rectifiers)		Result	If "No", why and suggested repair
A. Is all electronic monitoring equipment "on"?		<input type="checkbox"/> Yes <input type="checkbox"/> No	Date repaired
B. Is all electronic monitoring equipment "operating properly"?		<input type="checkbox"/> Yes <input type="checkbox"/> No	
2. Spill Buckets, Covers and Sensors			
A. Are all spill buckets clean and free of solid and liquid material?		<input type="checkbox"/> Yes <input type="checkbox"/> No	
B. Are all spill buckets and covers free of cracks and holes?		<input type="checkbox"/> Yes <input type="checkbox"/> No	
C. If applicable, are all spill bucket sensors positioned in accordance with manufacturer's specifications?		<input type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> NA	
3. Fill cover color-coding			

A. Are all grade-level fill covers color-coded in compliance with API RP 1637?	<input type="checkbox"/> Yes <input type="checkbox"/> No		

1.  
√